

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225558
Address: 1532 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, January 23, 2023

Corrective Action Required:

1	Misc	-fire block furr down ends -fire block vertically horizontal every 10' -support for down in finished storage room Fireblock materials code R302.11.1 of 2018 IRC
---	------	---

Comments: