

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220707  
Address: 3124 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, January 23, 2023

Corrective Action Required:

1 Misc

- furr down for hvac in garage and fire block
- fireblock for hvac chase at garage entry coat closet
- seal penetrations in
- address s3.2 10 connection at deck
- address incorrectly installed hangers above great room for floor joists at stairwell wall, above entry, above dining room
- missing anchors in steel column at stairwell

**Comments:**