## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20215283

Address: 3647 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:C, LEES SUMMIT, MO

640643647 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:E, LEES

SUMMIT, MO 640643647 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Gas Service Inspection - Khanh Nguyen Failed Tuesday, January 24,

Commercial 2023

Corrective Action Required:

1 Misc -Unit A, provide min 10 psi gas test pressure

Comments: