

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20226145
Address: 1499 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Tom Taylor	Passed	Tuesday, January 24, 2023

Informational:

1 Misc

1-20-23 RH. Contractor proof rolled the drive lane and the subgrade held up correctly. Approved to pour.

1-24-23 RH. Contractor used a dump truck for a proof roll of the parking spaces. Aggregate held the weight and passed the proof roll. Contractor will pour concrete today.

Comments: