

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220896

Address: 1071 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811073 NW BLACK TWIG CIR, LEES SUMMIT, MO
640811075 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811069 NW BLACK TWIG CIR,
LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Tuesday, January 24, 2023

Corrective Action Required:

1	Misc	1069-OK
		1071- Address broken truss at stairwell
		1073-Nail corner studs at garage, address broken truss near stairs
		1075-strap top plate at master

Comments: