

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216309
Address: 2014 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, January 24, 2023

Corrective Action Required:

1 Misc

- midway strap all dwv 2" or less in diameter in stud space(garage entry bath)
- fire block E dining room walls to ceiling space
- missing nails in hangers above kitchen/gathering room
- complete fireplace install for gas test
- missing 2 2x6 full height at front entry wall
- fire block wall space to ceiling space in laundry
- 2 2x6 either side of front stoop either side as shown on plans
- 2 2x4 at 2nd floor landing per plans
- provide future vent for future basement bathroom
- provide outlet for HVAC equipment service outside

Comments: