# Hernly

ASSOCIATES, Inc.

Architects & Environmental Consultants

1100 Rhode Island Street Lawrence, Kansas 66044-2868 Ph. 785.749.5806 Fax 785.749.1515

January 3, 2023

Planning & Development Division City Hall 220 SE Green St. Lee's Summit, MO 64063

RE: FDP Application: PL2021278 Permit No: PRCOM20225614 Project Title: LAKEWOOD SELF STORAGE Project Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064 Parcel Number: 4360003880000000 Location: LAKEWOOD BUSINESS PARK LOT 33A & LOTS 34-36---LOT 35 Type of Work: NEW COMMERCIAL Occupancy Group: STORAGE, MODERATE HAZARD Description: NEW SELF STORAGE BUILDING

Please accept this submittal with all accompanying documents as design response to the staff comments.

Below are enumerated responses to applicable comments:

### Planning Review:

- 1. Roof hatch detail added to roof plan sheet A5.1 with required guard rails.
- 2. Spec sheets for mechanical equipment provided by Strickland Construction as a part of this resubmittal.

### Licensed Contractor Notes/Comments:

1. Acknowledged

### **Building Plan Review Notes/Comments:**

- 1. Final Development Plan has been sent to Lee's Summit Development Services.
- 2. Special Inspections required have been added to Cover Sheet.
- 3. Acknowledged.
- 4. Acknowledged.

- 5. Acknowledged.
- 6. Required plumbing fixture calculations have been added to the Cover Sheet, and two additional restrooms have been added to the second floor of the building.
- 7. Rooftop unit screens have been added to the roof plan, building elevations, as well as a detail section through screen wall. The minimum height of the screens (46") was verified by the mechanical engineer to be at least as tall as the installed condenser units.
- 8. Roof hatch detail added to roof plan sheet A5.1 with required guard rails; Door, Window and Finish schedules on sheets A6.1 and A6.2. Exterior finish schedules have been updated and can be found on elevation sheets A3.1 and A3.2.
- 9. Roof hatch detail added to roof plan sheet A5.1 with required guard rails.
- 10. Sheet E1.1 revised indicating an exit sign to be located on first floor door #10 at Stair B.

## Fire Plan Review Notes/Comments:

- 1. Acknowledged.
- 2. Acknowledged.
- 3. Acknowledged.
- 4. Acknowledged.
- 5. Acknowledged.
- 6. Acknowledged.

Thank you for your attention to this submittal. If there are questions regarding this submittal, please do not hesitate to contact me.

Sincerely,

Stanley Hernly, AIA, NCARB Project Architect

