

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222664
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Wednesday, January 25, 2023

Corrective Action Required:

1	Misc	-Protect all DWV within 1.25" to face of framing-Horizontal runs through studs -Seal all plate penetrations concealed in combustible framing-Dwv in mechanical room -Seal through penetrations in firewall -Relocate water and DWV lines in electrical panel working space
---	------	---

Comments: