

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225202
Address: 880 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, January 25, 2023

Corrective Action Required:

1	Misc	-Provide box extension in suite 105 -Provide GFCI protection at receptacle in break room -Provide accessible restroom signage -Open faced toilet seat required -Move side wall grab bar to min. 54" from back wall
---	------	--

Comments: