CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20222245 Address: 1430 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:	
Electrical Service Inspo	ection Khanh Nguyen	Failed	Wednesday, January 25, 2023	
Corrective Action Requ		- f		
1 Misc	**Provide revised pla	**Provide revised plan for the service. The plan shows 600 amp service		
	-Need access to water disconnect must be gr (GEC) to water sized p copper GEC is require **If only one common ground both service d than 1/0 copper. Each connected to the com -Compliance with 250 the grounding electro that the service groun jumper from the equi	 **Current service configuration deficiencies: Need access to water grounding inside building. Each 225 amp service disconnect must be grounded to water with grounding electrode cond (GEC) to water sized per 250.66 based on the size of the service conductor per GEC is required for 4/0 cu service conductor. **If only one common grounding electrode conductor to water is instaground both service disconnects, then the common GEC size shall be not than 1/0 copper. Each separate GEC to each service disconnect shall be connected to the common GEC with irreversible splice -Compliance with 250.24(A) or (A)(4)-Inside each service disconnect, conthe grounding electrode conductor to the grounded bus bar (either left that the service grounded conductor is connected to; or install conduct jumper from the equipment grounding bus bar where the GEC is connected bus bar 		

Comments: