



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110702, Building Permit - Commercial
Address: 425 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	John Borns	Partial	Thursday, May 12, 2011

Partial Correction
1 MISC

STUDOR VENTS WILL BE ALLOWED AT ISLAND SINKS AT NURSE
STATION 144

Comments: