

DEVELOPMENT SERVICES

Residential Plan Review

January 26, 2023

GALE HOMES II INC 400 SW LONGVIEW BLVD, Unit 109 LEES SUMMIT, MO 64081 (816) 761-9292

Permit No: PRRES20230111

Plan Name:

Project Address: 197 SW WINTER RD, LEES SUMMIT, MO 64081

Parcel Number: 258804

Location: THE RIDGE AT WINTERSET SUMMIT LOTS 1600-1605 AND TRACT A --- LOT 1602

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE. PARTIAL SUSPENDED GARAGE SLAB. FINISHED/UNFINISHED BASEMENT. WALK OUT

BASEMENT. COVERED DECK. ENGINEERED FLOOR SYSTEM - DEFERRED. BUILDING ON FILL. 400 AMP

ELECTRIC. ELEVATOR.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Andrea Sessler Rejected

- 1. The legal description, including plat or phase number and lot number, and street address must be provided on the plot plan.
- 2. All easements with dimensions must be provided on the plot plan.

FRONT YARD HAS 10' U/E NOT 15'.

3. Basement egress location(s) and elevation of the lowest adjacent grade must be provided on the plot plan.

WALKOUT FROM HOUSE NEEDS DOOR LAG.

4. DESIGNED HOLLOW CORE SUSPENDED SLAB PLANS NEED TO BE UPLOADED.

Residential Plan Review Reviewed By: Andrea Sessler Rejected

1. Designate locations of smoke detectors and carbon monoxide detectors. (IRC Section R314 and R315)

SD AND SD/CM FOR BASEMENT "FUTURE GUEST ROOM". SD/CM OUTSIDE GUEST ROOM ON MAIN LEVEL.

- 2. Identify type of protection used in unfinished areas under floor trusses. (IRC Section R302.13)
- 3. Identify type of joist package or floor truss package (if used) complete with layouts, fastening details, blocking and bracing requirements and minimum sheathing.

DEFERRED.

4. PLEASE PROVIDE HOLLOW CORE SUSPENDED SLAB DESIGN PLANS. THANK YOU.

Planning Review RES Reviewed By: Not Required

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Residential, Decks Residential, Finished basements		404 2196	
Residential, Living Area (Not Finished	Basement)		
Residential, Un-Finished basements		925	
Roofing Material		Number of Bathrooms	4.5
Number of Bedrooms	4	Number of Stories	1
Number of Living Units	1	Total Living Area	5317