

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222242
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, January 26, 2023

Corrective Action Required:

1	Misc	-Ground service to water and ufer rebar -Install 400 amp fuse for service disconnect -Provide 4/0 copper tap feeder conductors for 225 amp breaker -Submit change to service riser diagram
---	------	---

Comments: