

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215090

Address: 3683 NE AKIN DR, Unit:B, LEES SUMMIT, MO 64064
3683 NE AKIN DR, Unit:C, LEES SUMMIT, MO 64064
640643683 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, January 27, 2023

Corrective Action Required:

1	Misc	-Final grade, sod, splash blocks -Flashing above horizontal protrusion at service -Seal exterior wall penetrations, lights -Paint gas service piping -Complete electrical to unit C AC
---	------	--

UNIT A-OK

UNIT B:

-Install box extensions for kitchen countertop receptacle boxes

UNIT C-OK

Comments: