

# CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

## PLAN REVIEW CONDITIONS

May 12, 2011

SLEEP ONE

699 NW BLUE PKWY

LEE'S SUMMIT, MO 64086

Permit No: PRCOM20111175  
Project Title: SLEEP ONE  
Project Address: 699 NW BLUE PKWY, LEES SUMMIT, MO 64086  
Parcel Number: 51700040900000000  
Location: SUMMIT FAIR 3RD PLAT LOTS 15-27 & TRACTS F-I---LOT 17  
Type of Work: New Tenant Finish  
Occupancy Group: Mercantile  
Description: SET OCCUPANCY FOR RETAIL STORE. CONSTRUCTION OF THE SPACE WAS COMPLETED ON THE SHELL PERMIT

***The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.***

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Fire Plan Review**

**Reviewed By: Jim Eden**

**Approved**

1. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Submit a layout of alarm notification appliances.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing.

3. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of two, 2A:10B:C fire extinguishers. Verified at inspection.

4. Exit and emergency lighting shall be provided if not already part of the shell building.

Verified at inspection.

5. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Verified at inspection.

**Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Approved**

1. Exterior signage is not included in the building permit review. Please contact the Planning and Development Department at (816) 969-1600 for application, review and permit requirements.

Action required - This comment is for information purposes only.

2. This permit is to set the occupancy only. It does not include any plumbing, electrical, mechanical or construction work.

Action required - This comment is for information purposes.

\_\_\_\_\_ Approved to issue per the listed conditions.

\_\_\_\_\_ Do not issue per the listed conditions.

\_\_\_\_\_ Approved to construct foundation only per the listed conditions.

\_\_\_\_\_ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Applicant Name

\_\_\_\_\_  
Company Name

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***