



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20110739, Building Permit - Residential
Address: 101 SW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Mark Harding	Partial	Thursday, May 12, 2011

Corrective Action Required
1 MISC check bonding of pool motor at final

Underground Electrical Inspection - Residential	Mark Harding	Partial	Thursday, May 12, 2011
--	--------------	---------	------------------------

Corrective Action Required
1 MISC PARTIAL - FROM HOUSE TO RETAINING WALL.

GAS PIPING UNDER GROUND INSPECTION REQUIRED

Comments: