

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225301
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	John Jackson	Passed	Monday, January 30, 2023

Informational:
1 Misc 01/26/23 Thursday JMJ (SDI)
Collected first sample for the appropriate 60' of 4" PVC water main today.
01/30/23 Monday JMJ (SDI)
Sample passed.

Comments: