

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20213741  
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Commercial</b>	Robb Popp	Partial	Tuesday, January 31, 2023

Informational:

1 Misc

Components bonded:

-Pool steel (4) points, Sleeve for ADA lift

Corrective Action Required:

2 Misc

-Provide water bond

-Connect bonding to equipment pad location

-Secure perimeter surface bond 18"-24" from edge of water

**Comments:**