

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222104
Address: 1608 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, February 01, 2023

Corrective Action Required:

1 Misc

- missing hanger on triple lvl above garage
- fire block furr out wall in garage to ceiling space
- address over notched wall stud for anchor bolt garage E wall
- fire block garage N wall into furr down
- provide weld certificate for beams welded together
- furr out for pex in dining
- fire block dining room E wall to ceiling space
- address holes drilled closer than 2" to one another above dining room
- address penetration in top plate above laundry
- stud packs above fire place for 2nd story
- stud pack in bed 4 closet
- collar ties for ridge above 2nd story hall
- address cut joist above basement mechanical area
- bond gas line
- solid block 48" OC in basement per plans
- address holes drilled closer than 2" to each other in double for pex NE basement

Comments:

