

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220794  
Address: 499 SW TOWER PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	Shawn Hoffman	Partial	Wednesday, February 01, 2023

Corrective Action Required:

1	Misc	- BONDING RING IN PLACE AT 30" WITH 10 ATTACHED BONDING WIRES. OK
PARTIAL, REINSPECT WHEN BONDING TO EQUIP. IS COMPLETE.		

**Comments:**