

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20216391  
**Address:** 2040 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Residential</b>	Mitchell Schwarz	Failed - Stop Work	Wednesday, February 01, 2023

**Corrective Action Required**

1	Misc	Inspection denied due to erosion control not in compliance.
<b>Corrective Action Required</b>		
2	Misc	STOP WORK ISSUED underslab plumbing covered without inspection.

**Comments:**