

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220899

Address: 1024 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811026 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811028 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811030 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811032 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811034 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811036 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811038 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811040 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811042 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811044 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811046 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811022 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Wednesday, February 01, 2023

Corrective Action Required:

1	Misc	1022 ok
		1024 ok
		1026 ok
		1028 anchor bolts
		1030 ok
		1032-Bonding screw and jumper at kitchen wall and ceiling
		1034 ok
		1036 ok
		1038-support sec,protect dryer ducts

NOT INSPECTED:

1040
1042
1044

Comments: