

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Robb Popp	Partial	Wednesday, February 01, 2023

Corrective Action Required:

1	Misc	12/21/22-OK TO POUR GB LINE 10, B-R
---	------	-------------------------------------

Informational:

2	Misc	EXTERIOR GRADE BEAM AND PAD: LINE T: 1-10; LINE 10: T-B LINE 1: T-L LINE A: 4-9 LOWER CORNER FOOTING, STEP FOOTINGS AND FOUNDATION WALLS AT SW CORNER LINES A/10
---	------	---

INTERIOR COLUMN PADS-OK TO POUR:

-LINE 2: D TO T
-LINE 3: E TO T
-LINE 4: E TO T
-LINE 5: F TO T
-LINE 6: F TO T
-LINE 7: G TO T
-LINE 8: G TO T
-LINE 9: G TO T

UFER LOCATED AT NE CORNER AT 1/R LINES

- 11/17/22 INTERIOR COLUMN PADS OK TO POUR
DETAIL 6.0 (17) DETAIL 7.0 (7)
LINE F TO C LINE 2 TO 10
LINE 9 & LINE B (1) 7.0 DETAIL
LINE B LINE 2 TO 8 NOT READY AT THIS TIME -

-1/24/23 FOOTINGS AT NORTH SIDE FOR TRASH ENCLOSURE OK

Comments: