

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214592  
Address: 809 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
807 NE ALGONQUIN ST, LEES SUMMIT, MO 64064  
805 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, February 01, 2023

Corrective Action Required:

1	Misc	UNIT 805-OK
---	------	-------------

UNIT 807:

- Install floodlight bulbs
- Bottom support brackets for garage door track must be at 10" above floor
- Remove foundation wall ties in basement

UNIT 809-OK

\*\*TCO approved for units 805&809 only

**Comments:**