



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110514, Building Permit - Commercial  
Address: 695 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Friday, May 13, 2011

Corrective Action Required  
3 MISC

PLUMBING SCHEDULE ON DRAWING SHOWS TRAP PRIMER ON FD-2, WHICH IS NOT IN PLACE; OK TO COVER WITH THIS EXCEPTION

**Comments:**