

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20221592  
Address: 230 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Wednesday, February 01, 2023

Informational:

1 Misc

Screw pattern at demising wall ok-Seal all penetrations  
-1st, 2nd layer under stairs ok

North side-PATCH HOLES STUD TO STUD AND SEAL GAPS, EXTEND ROCK TO  
BOTTOM OF FLOOR AT STAIRS

**Comments:**