

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213741
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|------------------------------|
| Pool Steel/Bonding - Commercial | Robb Popp | Passed | Wednesday, February 01, 2023 |

| | |
|----------------|---|
| Informational: | |
| 1 Misc | Components bonded: -Pool steel (4) points, Sleeve for ADA lift, Perimeter surface, to equipment pad, handrail, water |

Comments: