



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20230196, Public Works Right of Way Permit

Address: 4871 SW RAINTREE PKWY, LEES SUMMIT, MO 640824801 SW RAINTREE PKWY, LEES SUMMIT, MO 64082222 SW TILLER CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Partial	Thursday, February 02, 2023

Corrective Action Required

1 Misc

Site Visit - The installation work should be complete. The contractor did somehow hit a power line going to the lights. Black and McDonald was called out after hours and discovered the hit. Bob and I met onsite with the contractor and Kenny from Black and McDonald. The contractor stated they called in a dig up ticket. Black and McDonald stated the tech that came onsite thought they had cut the wires in a junction box. From what we saw it did not look like wires were cut, they were more than likely just pulled out from the bored head hitting the wire. This is still being investigated.

Comments: