

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216309
Address: 2014 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, February 02, 2023

Corrective Action Required:

1 Misc

- missing nail in hanger above kitchen/gathering room
- secure gas line at fire place
- missing 2 2x6 full height at front entry
- provide outlet for HVAC equipment service outside E3901.12

Comments: