

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215278

Address: 3667 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643667 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643667 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643667 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Friday, February 03, 2023

Corrective Action Required:

1	Misc	-Support AC lines in attic
		UNIT A:
		UNIT B:
		-Protect clothes washer wiring at bottom wall plate
		UNIT C:
		UNIT D:
		-Fully nail laundry/bathroom wall stud shoe
		-Complete installing switch at master bathroom

Comments: