

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215278

Address: 3667 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643667 NE AKIN DR, Unit:C, LEES SUMMIT, MO
640643667 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643667 NE AKIN DR, Unit:A, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Friday, February 03, 2023

Corrective Action Required:

1	Misc	-Provide min ten psi pressure for testing
---	------	---

Unit D is OK. All other units have either zero or less than 10 psi test pressure

Comments: