

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222881
Address: 370 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, February 03, 2023

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Provide anchor bolt garage sill plate near entry closet- Address valley rafter in mud room over notched- Fb seal gaps vertical to horizontal at top of offset dining room exterior wall- Bathroom vent ductwork to be 4" , 3" not allowed- Missing office window- Fb top of chase, wedge near stairs main floor- Security blocking basement door |
|---|------|--|

Comments: