CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Footing Inspection - Robb Popp Partial Friday, February 03,

Commercial 2023

Corrective Action Required:

1 Misc 12/21/22-OK TO POUR GB LINE 10, B-R

Informational:

2 Misc EXTERIOR GRADE BEAM COMPLETE

FOOTINGS FOR TRASH ENCLOSURES AND GENERATOR COMPLETE

INTERIOR COLUMN PADS-OK TO POUR:

-LINE 2: D TO T -LINE 3: E TO T -LINE 4: E TO T -LINE 5: F TO T -LINE 6: F TO T -LINE 7: G TO T -LINE 8: G TO T -LINE 9: G TO T

UFER LOCATED AT NE CORNER AT 1/R LINES

DETAIL 6.0 (17) DETAIL 7.0 (7) LINE F TO C LINE 2 TO 10 LINE 9 & LINE B (1) 7.0 DETAIL

LINE B LINE 2 TO 8 NOT READY AT THIS TIME -

Comments: