City of Lee's Summit

Applicant's Letter

220 SE Green Street Lee's Summit, Missouri 64063 (816) 969-1600 Fax (816) 969-1619

Fireworks Permit

Date: Friday, May 13, 2011

Application Number: PRFW20110521

To:

LONE JACK FIREWORKS, shelly@wincofireworks.com <NO FAX NUMBER>

LLC

YOUNG LIFE LEE'S SUMMIT < NO FAX NUMBER>

TI SUMMIT CREST PLAZA <NO FAX NUMBER>

LLC

From: Hector Soto, Planner

RE: PRFW20110521,

Applicant: LONE JACK FIREWORKS, LLC, Address:1992 WUS-50 HWY.

Address: 3500 SW MARKET ST, LEES SUMMIT, MO 64082

Conditions:

Special Event Firework Sales approved. See below and attached for any conditions of approval.

Building Codes Review (FW)	Mike Copeland	Manager of Building Inspections	(816) 969-1204	Pending
Building Codes Review (FW)	Mike Copeland	Manager of Building Inspections	(816) 969-1204	Pending
Fire Codes Review (FW)	Jim Eden	Assistant Chief	(816) 969-1303	Pending

^{1.} General Comments-Every seasonal retail sales location shall have not less the two (2) portable fire extinguishers with a minimum 2A rating, with at least one (1) of which shall be a pressurized water type.

Certification of recognized standards or manufacturer verifying the tent fabric has been treated with a flame resistant material.

NO hay, straw, shavings, or similar combustible materials that have not been treated to make them flame retardant shall be permitted within any seasonal retail location.

At least one (1) sign at each entrance that reads as follows, in letters at least four inches (4") high on a contrasting background shall be conspicuously posted at each entrance of seasonal retail sales locations: NO FIREWORKS DISCHARGE WITHIN 100 FEET.

At least one (1) sign at each entrance that reads as follows, in letters at least four inches (4") high on a contrasting background shall be conspicuously posted at each entrance of seasonal retail sales locations: FIREWORKS NO SMOKING

At least (1) sign, to be provided, showing Prohibited Fireworks Within the City of Lee's Summit shall be conspicuously posted at the entrance of seasonal retail sales locations.

All person(s) selling fireworks or offering fireworks for sale shall permit the State Fire Marshal and the marshals deputies, the Lee's Summit Fire Department, and the Codes Administration for the City of Lee's Summit to conduct inspections, based on the Code of State Regulations, the International Fire Code, and the International Building Codes on any and all seasonal retail sales locations prior to the seasonal retail sales location opening to the public and during normal business operations.

Tents, canopies or membrane structures shall not be located within 20 feet (6096 mm) of lot lines, buildings, other tents, canopies or membrane structures, parked vehicles or internal combustion engines. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the temporary membrane structure, tent or canopy.

No person shall throw, use, explode, detonate, or shoot fireworks within three hundred (300) feet of any permanent storage of ignitable liquids, gasoline pump, gasoline filling station, or any non-permanent structure where fireworks are stored, sold or offered for sale.

Planning Review (FW)	Hector Soto	Planner	(816) 969-1604	Correction
				S

1. A business license shall be obtained from the City of Lee's Summit Finance Department and a cash deposit, performance bond, letter of credit or other security approved in content and form by the City Attorney in the face amount of \$1,000 shall be provided to the Finance Department no later than June 16th.