

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20221120  
Address: 1037 SW ARMIE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, February 07, 2023

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 2 | Misc | <ul style="list-style-type: none"><li>- Attach fireplace</li><li>- Fb ends of soffit in kitchen</li><li>- Anchor steel column first floor</li><li>- Fb bottom of fur outs in garage</li><li>- Nail exterior corner back of single garage</li><li>- Anchor bolt at plate breaks garage both side</li><li>- Nail off straps for PFH</li><li>- missing nut on PFH hold down anchor</li><li>- Security blocking garage man door</li><li>- Fur out bathroom vent ductwork in garage</li><li>- Address rafters landing on blocks</li><li>- Add soffit and correct but stud in pantry</li><li>- Nail joist hangers bedroom 2</li><li>- Nail all exterior corners</li><li>- Anchor steel columns in basement</li><li>- Address cut joint behind furnace in basement</li><li>- Open deck roof for inspection</li></ul> |
|---|------|---|

Comments:

