

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20216391
Address: 2040 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mitchell Schwarz	Failed - Stop Work	Tuesday, February 07, 2023

Corrective Action Required

1 Misc

Inspection denied due to erosion control not in compliance.

Corrective Action Required

2 Misc

STOP WORK ISSUED

underslab plumbing covered without inspection.

Corrective Action Required

3 Misc

-Dye test failed

-Camera test and provide results before proceeding with any repairs.

Comments: