

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222560

Address: 451 SE OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Robb Popp	Passed	Wednesday, February 08, 2023

Informational:

1	Misc	-New gas line to North paint booth pressure test ok -New line to South booth pressure test ok
---	------	--

Comments: