

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PR20222818  
Address: 451 SE OLDHAM PKWY, Unit:C, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Wednesday, February 08, 2023

Corrective Action Required:

1	Misc	-Complete corrections for all other departments (fire and water) -Provide address for building on street side of building -Provide access to attic for above ceiling inspection at hard lids -Provide accessible restroom signage -Label panels -GFCI at SE exterior corner not working -Paint exterior gas lines with corrosion resistant paint
---	------	--

Comments: