

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222560

Address: 451 SE OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Wednesday, February 08, 2023

Corrective Action Required:

1	Miscellaneous Correction	-Provide address at street side of building -Paint all exterior gas lines with corrosion restraint paint -Label panels -Provide panel schedules -Remove equipment in front of panels
---	--------------------------	--

Comments: