

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216495
Address: 101 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, February 08, 2023

Corrective Action Required:

1	Misc	- Garage stairs guard at bottom of spindles - Provide 6" clearance from siding to grade - Secure electrical whip at water heater - No Pier inspection on covered patio
---	------	---

Comments: