

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220450
Address: 4704 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, February 10, 2023

Corrective Action Required:

1	Misc	-Approved as-graded plot plan is required -Provide AFCI protection for all outlets required per NEC 210.12. (Dishwasher & disposal) -Receptacle at furnace switch shall be gfci-protected
---	------	---

Comments: