

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226111
Address: 1329 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Khanh Nguyen	Failed	Friday, February 10, 2023

Corrective Action Required:

1	Misc	-Provide AFCI protection for all outlets in finished basement -Provide spark rings for electrical boxes recessed more than 1/4" behind non-combustible wall finish at wet bar countertop
---	------	---

Comments: