

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223255
Address: 2781 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, February 10, 2023

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- Replace screws in stud shoes to nails or structural screws all stud shoes throughout- Missing nails in joist hangers kitchen at double Lvl- Add support to ridge beam master bedroom at bathroom- Fb basement sofa both ends. I- beam bottom of stairs- Tighten anchor bolts basement- Rep
---	------	---

Comments: