

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220114
Address: 2035 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, February 13, 2023

Corrective Action Required:

1	Misc	-complete cspf in dinning provide documentation/engineer letter for alternative cspf design
---	------	---

Method ABW REQUIRES 32" panel length for 9' wall per table 602.10.5
Provide engineered correction

Clarify design and usage of design, stated design is used for concrete. I.E lag bolt size, hold down type, straps to attach to.

Mitch Schwarz 2/13/22 09:47

Okay to insulate

Comments: