

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222149
Address: 2808 SW HEARTHSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, February 13, 2023

Corrective Action Required:

2 Misc

- address pending underground plumbing and electrical inspection
- sod-splash blocks and sump pump discharge to extend 36" from foundation
- bring water meter well to grade. Ensure 14"-18" from meter top to well lid ring
- label all non GFCI outlets in unfinished spaces

Comments: