

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221737
Address: 4732 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, February 13, 2023

Corrective Action Required:

1	Misc	-Shim gap at deck joist hangers -Provide graspable handrail no wider than 3.5"for deck stair -Provide an outdoor receptacle accessible from grade and within 6.5 ft of grade at back of dwelling -Paint gas service piping to protect against corrosion -Provide sewer tracer wire port at grade -Provide max 35 amp breaker for AC unit circuit
---	------	---

Comments: