CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221415

Address: 2030 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Monday, February 13,

Residential 2023

Corrective Action Required:

1 Misc -Address pending peir inspection

-Complete final grad, sod, splash blocks etc.
-Secure exterior receptacle at front entry
-Sheet rock bottom of furout wall in garage
-Label non gfci protected receptacles throughout

-Remove covers at smoke detectors-Micowave circuit to be AFCI protected

-Correct gap larger than 1/8" at side of box in pantry

-Sheet rock under landing at enclosed stairs in sump pump access

-Provide secondary lock at sliding glass door in basement

-Install stairs at exterior basement wo/wu

-Secure whip st ac

-Lockout range hood breaker

-Seal top of meter can and all exterior penetrations

Comments: