

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20221409  
Address: 2022 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, February 13, 2023

Corrective Action Required:

1 Misc

- address missing player under header at pfg
- all anchor bolts to be in the middle third of sill plate and tight
- furr out and fire block for return air in garage
- nail all exterior wall corner studs together to code
- nail off double ceiling joist above dining hanger multiple hangers missing nails
- missing nails in hanger above kitchen/great room
- 2 (3) 2x6 floor to ceiling per plans at fire place
- fire block W great room wall to ceiling space. Seal gaps
- hangers for ceiling joist above great room /entry
- solid block sheathing breaks at master /master bath W wall
- 2 2x6 full length at front entry either side per plans
- uncover covered post D for inspection. Ensure 3 1/2" sch 40 steel column
- address exterior wall studs over notched for anchor bolts in basement multiple though out
- addled holes drilled closer than 2" to one another above billiards area in basement
- fire block furr down beam ends throughout basement
- all anchor bolts to be tight and in the middle 1/3 of sill plate in basement
- seal penetrations in R/a joist space above great room/billiards area

- mid way strap all 2" in diameter or less dwv in stud bays
- fire block dead space at basement bath wall to ceiling space
- fire block basement bed room bath to bed 4 ceiling space
- fire block furr down ends in bed 4
- double ever other floor joist above basement beds bath per plans
- provide pressure for gas line inspection

-

**Comments:**