CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222472

Address: 2103 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Monday, February 13,

Residential 2023

Corrective Action Required:

1 Miscellaneous - provide anchor bolt garage at plate break

Correction - Anchor bolt to the middle third of plate at garage near entry

- Shim studs under windows in dining room

- Finnish sheeting deck area and solid block sheeting breaks

- Fb penetration top plate great room east side

- Fb ceiling height change master bathroom at DWV above vanity

- Support soffits wider than 4' to joist above

-

Comments: