

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216390  
Address: 1705 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, February 10, 2023

Corrective Action Required:

1 Misc

- outlets in kitchen will not re set
- 2 1/2" through bolts at deck post to beam connection
- complete A/c install
- check water meter at time of sod. (Ensure meter well flush height and meter depth in well 14"-18")
- label all non GFCI outlets in unfinished spaces

**Comments:**